

Hangzhou Tangpushi Home Products Co.,Ltd

TEST REPORT

SCOPE OF WORK

curtain

REPORT NUMBER

240204007SHF-001

TEST DATE(S)

2024-02-04 - 2024-02-27

ORIGINAL ISSUE DATE

2024-02-27

PAGES

6

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(February 1, 2024)

© 2024 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on the assigned page.
- 2.This report is invalid without an authorized person's signature.
- 3.This report is invalid if altered.
- 4.Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Don't copy this report in partial without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.
- 6.Except for the obligation, responsibility and liability (if any) for the appropriateness and professionalism of afore-mentioned testing itself within the scope and amount of the testing fee received, Intertek does not and will not accept any other obligation or liability.
- 7.If the Client has any questions about the test results, Intertek B&C should be informed within the storage period of the samples. The sample storage period ends 5 working days after the official report issue date. Samples of certification program are retained for the period required by the certification rules. The samples storage period shall be calculated according to the issue date of the original report in the case of quoting results and modifying reports.
- 8.Intertek B&C will service this report for the entire test record retention period. The test record retention period ends 6 years after this report original issue date. The test record retention period for certification program is 10 years. Test records and other pertinent project documentation will be retained for the entire test record retention period.
- 9.The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.



Test Report

Original Issue Date: 2024-02-27

Intertek Report No. 240204007SHF-001

Applicant: Hangzhou Tangpushi Home Products Co.,Ltd

Address: Room 1502,Building 2, 22 Nanyuan St, Hangzhou, Zhejiang, China

Attn: Xiaohua Chen

Manufacturer: Haining Tingpei Textile Co.,Ltd

Address: 3F, 3 Building,3 Xingcheng Rd,Xucun Town,Haining,Zhejiang

Test Type: Performance test, samples provided by the applicant.

Product Information

Product Name	Model	Specification
curtain	Gene	Width : 59 inch
Sample ID	Sample Amount	Sample Received Date
S240204007SHF.001	2 pcs	2024-01-18
Sample Description		
Thickness 1.4mm		

Test Methods And Standards

Test Standard	ASTM C423-22
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report does not involve sampling. The report only reflects conformity of the tested items of the samples provided by the testing applicant. Representativeness and authenticity of the submitted samples are responsibilities of the testing applicant.

Report Authorized


Ozzy Cheng Jackie Zhou
Name: Ozzy Cheng Jackie Zhou
Title: Reviewer Project Engineer

Test Report

Original Issue Date: 2024-02-27

Intertek Report No. 240204007SHF-001

Test Items, Method and Results:


Test Method: ASTM C423-22 Sound Absorption Coefficients

Volume of the reverberation room	Vs, m ³	240	Installation Type:	G-75
Room temperature	t1, °C	10	t2, °C	10
Relative humidity of test rooms	H1,%	54	H2,%	54

Sample description:

Sample size (width*length),mm	1500*4650	Thickness, mm	1.4
Edge treatment	/	Mass, kg/m ²	1.4
Test Area, m ²	7.0		

Frequency (Hz)	αs
100	0.01
125	0.00
160	0.00
200	0.12
250	0.16
315	0.22
400	0.25
500	0.31
630	0.37
800	0.45
1000	0.50
1250	0.53
1600	0.52
2000	0.54
2500	0.57
3150	0.54
4000	0.55
5000	0.65
NRC	0.40
SAA	0.38



Test Report

Original Issue Date: 2024-02-27

Intertek Report No. 240204007SHF-001

Appendix A: Test Photos



Test set up



Test Report

Original Issue Date: 2024-02-27

Intertek Report No. 240204007SHF-001

Appendix B: Sample Received Photo



Revision:

NO.	Date	Changes
240204007SHF-001	2024-02-27	First issue